



सत्यमेव जयते

**Government of West Bengal**

**Office of the Divisional Fire Officer**

**West Bengal Fire & Emergency Services**

**Paschim Bardhaman Division, 1st Floor, Durgapur Fire Station Building, City Centre, Durgapur-16**

**Memo No.: FSR/IND/WB/FES/20172018/8721**

**Date : 10-03-2025**

**From :**  
**Divisional Fire Officer**  
**Paschim Bardhaman Division,**  
**West Bengal Fire & Emergency Services**

**To :**  
**CITY MONTESSORI SCHOOL OF MOULVI YASIN EDUCATIONAL TRUST DIRECTOR SYED MOHAMMAD AZHAR and Others.**  
**AT KALAJHARIA, PIPE LINE ROAD GUTGUT PARA,WARD NO-94 UNDER AMC BOROUGH VII,PO-BURNPUR,PS-HIRAPUR,DIST-PASCHIM BARDHAMAN,PIN-713325 UNDER ASANSOL MUNICIPAL CORPORATION.**

**Sub : Renewal of Fire Safety Certificate in favour of an existing construction of G+I storied building under group educational occupancy, in favour of CITY MONTESSORI SCHOOL OF MOULVI YASIN EDUCATIONAL TRUST DIRECTOR SYED MOHAMMAD AZHAR AND OTHERS. at the Premises/Holding no- Kalajharia, Pipe Line Road Gutgut Para, Ward No-94, Borough-VII & P.O.- Burnpur, P.S.- Hirapur, Dist-Paschim Bardhaman, Pin-713325 under Asansol Municipal Corporation.**

This is in reference to your AIN 211912506300003847 dated 27-Jan-2025 regarding Renewal of Fire Safety Certificate in favour of an existing construction of G+I storied building under group educational occupancy, in favour of CITY MONTESSORI SCHOOL OF MOULVI YASIN EDUCATIONAL TRUST DIRECTOR SYED MOHAMMAD AZHAR AND OTHERS. at the Premises/Holding no- Kalajharia, Pipe Line Road Gutgut Para, Ward No-94, Borough-VII & P.O.- Burnpur, P.S.- Hirapur, Dist-Paschim Bardhaman, Pin-713325 under Asansol Municipal Corporation..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

**Recommendation:**



*Ansari*  
PRINCIPAL  
CITY MONTESSORI SCHOOL  
Affiliation No.- 2430386

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300003847

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. A fire control room including a closed-circuit TV system will have to be maintained which observe all floor of the building.
5. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.
6. If required old line shall have to be replace with new lines, the cables shall always be laid in M.S conduit pipes continuously bonded to the earth.
7. Periodical flushing of water in the hydrant and sprinkler pipe line shall be made to maintain the efficiency working performance of above-mentioned system.
8. Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.
9. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.
10. Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.
11. First aid firefighting system shall be provided as per I.S specification.
12. The notice of firefighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
13. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
14. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
15. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
16. The Renewal of Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Memo No.:

Valid Upto : 08-Mar-2028

FSR/IND/WB/FES/20172018/8721

*Halder*  
PRINCIPAL  
CITY MONTESSORI SCHOOL  
Affiliation No.- 2430386

Signature valid

Digitally Signed.  
Name: RATAN KUMAR HALDER  
Date: 10-Mar-2021 12:48:28  
Reason: D-Sign  
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300003847

