

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 3-08-26

It is certified that an inspection team headed by

A. MUKHERJEE, S.I. (Name of Officers with designation)

from ASANSOL MINES BOARD OF HEALTH, PHED

inspected the 3-08-2026 CITY MONTESSORI SCHOOL

(Name & Address of the school) on 3-8-26 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. AMB/LAB/FM/56

dated 3-7-25 of A. M. B. H. (PHED Lab)

certified that the

CITY MONTESSORI SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 2-08-2027

To
CITY MONTESSORI SCHOOL
KALAJHARIA PIPE LINE ROAD
(Name & Address of the Institution)
BURNPUR 713325

Signature with Seal:

Name ASHOK MUKHERJEE

Designation SANITARY INSPECTOR

Name & Address of the Office / Department:

ASANSOL MINES BOARD OF HEALTH
ASANSOL, N.S. ROAD
P.O. - ASANSOL, P.S. - ASANSOL (SOUTH)
DIST. - PASCHIM BARDHAMAN
W.B.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

SANITARY INSPECTOR

Bilarampur

A. M. B. H.



Asansol Mines Board of Health

Drinking water Testing Laboratory

Phone no- (0341) 225-2227

Email- ambhlaboratory@gmail.com

Address- DM bungalow Compound, Near- Asansol Court, Asansol, Paschim Bardhaman, West Bengal - 713304


Format No - AMBH/LAB/FM/56

Name of the Client and Address	Report No	AMBH/LAB/TR/143/2025
City Montessori School, Kalajharia Pipe Line Road , Burnpur, 713325	Report Issuing Date	03.07.2025
	Sample collected by	Party
	Sample type	Drinking Water
	Sample location	Tap From Location
	Sample received on	23.06.2025
	Sample condition	Sealed
	Period of Analysis	25.06.2025 -03.07.2025
Sample Returned / Stored	Stored at 4 °C for one week from the date of report release.	


Test report

Sl no	Parameters	Unit	Limit as per IS 10500:2012	Test method	Results
1	Odour		unobjectionable	IS:3025 Part-05	unobjectionable
2	Turbidity	NTU	5	IS:3025 Part-10	1.05
3	pH @ 27 °C		6.5-8.5	IS:3025 Part-11	6.60
4	Total Hardness (as CaCO ₃)	mg/l	300	IS:3025 Part-21	48.96
5	Total Alkalinity (as CaCO ₃)	mg/l	200	IS:3025 Part-23	30.79
6	Chloride (as Cl)	mg/l	250	IS:3025 Part-32	1.96
7	Nitrite Nitrogen (as NO ₂)	mg/l	0.10	IS:3025 Part-34	BDL
8	Ammoniacal Nitrogen	mg/l	0.10	IS:3025 Part-34	BDL
9	Calcium (as Ca)	mg/l	75	APHA 24 th Edition (3500)	8.18
10	Magnesium (as Mg)	mg/l	30	APHA 24 th Edition (3500)	6.94

❖ BDL- Below Detection Limit


Analyst

Reviewed by


Authorised Signatory

Quality is
AMBH LAB


HOD
**HOD
AMBH LAB**



Asansol Mines Board of Health

Drinking water Testing Laboratory

Phone no- (0341) 225-2227

Email- ambhlaboratory@gmail.com

Address- DM bungalow Compound, Near- Asansol Court, Asansol, Paschim Bardhaman, West Bengal - 713304

Format No - AMBH/LAB/FM/56

Report No

AMBH/LAB/TR/143/2025

Bacteriological Quality of Drinking water All water intended for Drinking

Sl No	Parameters	Requirements	Result
1	<i>E. Coli</i> or Thermo- tolerant Coliform Bacteria	Shall Not be detectable in any 100 ml sample	Not Detected
2	Total Coliform	Shall Not be detectable in any 100 ml sample	Not Detected

Remarks

Chemically: - Satisfactory for drinking Purpose.

Bacteriologically:- Satisfactory for drinking Purpose.

Note: -

1. The sample is not drawn by us.
2. The above test values are reported as per the sample received.
3. Sample(s) will be disposed after 7 days from the date of issue of the report.
4. The test report shall not be reproduced without written permission from laboratory

Analyst

Reviewed by

Authorised Signatory

**Quality Manager
AMBH LAB**

HOD

**HOD
AMBH LAB**